


BMP 064 - Restrict Access to Tanks



Description of Potential Pollutant and Source: Improper use or vandalism of fuel tanks may result in discharge of fuel to the ground. This fuel may then be exposed to storm water and transported to the storm drain and/or receiving waters.

Description of BMP: Access to the tank and valves will be restricted to properly trained personnel. The area can be restricted by a locked gate. This BMP is recommended for fuel tank farms.

Application Guidance: Access to valves will be restricted at all times to properly trained personnel.

Training: Personnel who use fuel tanks will be trained in the proper operation of the system. Non-trained personnel who need fuel will be informed how to contact trained personnel for fuel dispensing.

Effectiveness and Cost: This is an effective, low-cost BMP.

Limitations: The placement of some tanks may make it difficult to restrict access them.